



Indiana State  
Department of Health  
An Equal Opportunity Employer

Mitchell E. Daniels, Jr.  
Governor

Gregory N. Larkin, M.D., F.A.A.F.P.  
State Health Commissioner

June 30, 2010

VIA CERTIFIED MAIL, COPY REGULAR MAIL

Mike Kessler  
3940 N. 3580 W.  
Burlington, ID 83255

Dear Mr. Kessler:

Re: Plans and Specifications for  
a Replacement Septic System  
Skyview Mobile Home Park  
ISDH Project No. 2009283  
C.R. 21, 1/3-mi. north of C.R. 38  
Goshen, Elkhart County

The plans and specifications for a septic system to serve the existing 45-lot Skyview Mobile Home Park have been reviewed, and are hereby approved on this date.

This project includes the removal and replacement of all existing septic tanks, construction of an effluent collection system and a central dosing tank, and an absorption field on the west side of C.R. 21. The existing septic tanks will be pumped, crushed and removed. The existing sanitary sewers in the park will be reused.

There are nine (9) existing sanitary collection systems in the park serving the 45 lots. Each will discharge into a new septic tank or tanks prior to connecting to the proposed effluent collection sewer system. These *collection systems* are as follows:

- System #1 – Serves 7 lots; two (2) proposed 1,500-gallon septic tanks
- System #2 – Serves 4 lots; one (1) proposed 2,000-gallon septic tank
- System #3 – Serves 3 lots; one (1) proposed 1,250-gallon septic tank
- System #4 – Serves 4 lots; one (1) proposed 2,000-gallon septic tank
- System #5 – Serves 7 lots; two (2) proposed 1,500-gallon septic tanks
- System #6 – Serves 2 lots & barn; one (1) 1,250- & one (1) 1,000-gallon septic tank
- System #7 – Serves 5 lots; two (2) proposed 1,000-gallon septic tanks
- System #8 – Serves 7 lots; two (2) proposed 1,500-gallon septic tanks
- System #9 – Serves 6 lots; one (1) 1,500- & one (1) 1,000-gallon septic tank

The effluent collection sewer system consists of approximately 1,485 feet of 6-inch sewer pipe. The portion of the system within 100-feet of the well will be constructed of SDR 26 pipe with gasketed, compression fittings.